

HoKa Gesellschaft für Lüftungsformteile aus Kunststoffen mbH



HoKa GmbH • Reutherstraße 12 • D-53773 Hennef

Vink Finland OY Juha Kostian Silokalliontie 6

FI 04250 Kerava

Markus Schorn

Phone: (0049)2242/9251-50 Fax: (0049)2242/9251-20

Email: markus.schorn@hoka.de

13. März 2017

PPs (flame retardant polypropylene)

We herewith confirm that our ventilation formed parts Polypropylene (PP flame retardant) has been submitted for fire resistance testing (Brandschacht-Test) (material class B1) according to DIN 4102-1 (May 1998).

The material has met the requirements in the tested thickness according to the material class B2 according to DIN 4102-1 (May 1998). The results show that the material also fulfils the requirements of

Material class B1 burning droplets

According to DIN 4102-1 (May 1998).

The results are based on the test report No 2014-1147 (EXOVA).

With kind regards Markus Schorn -Plant Manager-